





# MODULAR GAS PARK SAFE COOKING SYSTEM MODEL MOD-G-03 CONSTRUCTION DETAIL

N.B. GAS BOTTLES MUST BE HOUSED EXTERNALLY ON THIS MODEL




TOP VIEW



BASE DETAIL



BRING UNDERGROUND SUPPLY PIPE UP TO THE RIGHT SIDE OF HOTPLATE OPENING LOOKING FROM THE FRONT AS INDICATED BY SHADED AREAS. DO NOT BRING PIPE UP DIRECTLY UNDERNEATH HOTPLATE AND ENSURE PIPE DOES NOT RUN UNDERNEATH HOTPLATE.



CONCRETE SLAB TO SUIT CUSTOMER REQUIREMENTS. SLAB SHOULD EXTEND MIN 900 OUTSIDE STRUCTURE FLUSH WITH SURROUNDING GROUND TO PROVIDE PAVED SURFACE FOR USERS TO STAND ON.